

FINISH NOTE

WALL & CEILING FINISHES:

PER IBC TABLE 603.5, GROUP B, NONSPRINKLERED, EXIT ACCESS - CLASS B & ROOMS - CLASS C.

IBC 603.1 GENERAL INTERIOR WALL AND CEILING FINISHES SHALL BE CLASSIFIED IN ACCORDANCE WITH ASTM E 84. SUCH INTERIOR FINISH MATERIALS SHALL BE GROUPED IN THE ACCORDANCE WITH THEIR FLAME SPREAD AND SMOKE DEVELOPED INDEXES.

CLASS A: FLAME SPREAD 0-25 & SMOKE DEVELOPED 0-450.

CLASS B: FLAME SPREAD 26-75 & SMOKE DEVELOPED 460-750.

INTERIOR FLOOR FINISHES:

IBC 604.2 CLASSIFICATION:

INTERIOR FLOOR FINISH AND FLOOR COVERING MATERIALS REQUIRED BY SECTION 604.5.1 TO BE OF CLASS I OR II MATERIALS SHALL BE CLASSIFIED IN ACCORDANCE WITH NFPA 253. THE CLASSIFICATION REFERRED TO HEREIN FOR CLASS I SHALL BE DETERMINED BY NFPA 253 AS FOLLOWS:

PER IBC 604.5.1, NONSPRINKLERED, EXIT ACCESS - CLASS B, ROOMS AREAS DOOR-1 MATERIALS ARE REQUIRED.

THERMAL & SOUND INSULATING MATERIALS NOTE:

IBC 119.3 CONCEALED INSTALLATION, INSULATING MATERIALS, WHERE CONCEALED AS INSTALLED IN BUILDINGS OF ANY TYPE OF CONSTRUCTION, SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED INDEX OF NOT MORE THAN 450.

KEYED NOTES

(20) IRRIGATION TIER CONTROL. SEE LANDSCAPING PLAN. VERIFY FINAL LOCATION. SEE ELEVATION 1010.0.

(21) BOLLARD. TYP.

(50) CART STORAGE BAILING SYSTEM. (CARRIAGE TRADE SERVICE CO. OR EQUAL.) 2-1/4" CHROME POSTS @ 48" O.C. AND 1-3/4" CHROME RAILS @ TOP & MIDSPAN. INSTALL PER TIER SHEET.

(100) FINE EXTINGUISHER. 2A-10BC. STAINLESS STEEL. SEMI RECESSED. BRACKET. FIELD VERIFY AND COORDINATE LOCATION.

(102) 4408BC FINE EXTINGUISHER WALL MOUNT W/ BRACKET @ 54" (MAX) A/F.F. TO TOP OF BRACKET.

(120) CHANGING ROOM ACCESSORIES: - 3" X 6" GLASS MIRROR W/ STAINLESS STEEL TRIM - (3) SEAT HOOKS IN PLASTIC LAMINATE BENCH - PLASTIC LAMINATE COUNTER TOP - 3/4" HT MAX W/ HARDWOOD EDGE AND 4" PLASTIC LAMINATE BACKSPLASH OVER LOWER CASEWORK W/ ADJUSTABLE SHELVING UNO.

ABOVE - 30" HT UPPER CASEWORK W/ ADJUSTABLE SHELVING, UNO.

SEE CASEWORK NOTES

(131) METAL BUILDING SYSTEM RAILING/SHADE DETAIL ABOVE

(132) METAL BUILDING SYSTEM GUTTER (DESIGN BY METAL BLDG MANFR) & LEADER (DESIGN BY MECHL ENGR) W/ CONCRETE FLASH BLOCK @ WIDE X (EXTEND TO FACE OF CURB) TYP AT GRADE TO PROVIDE POSITIVE DRAINAGE.

(133) STEEL GIRTS @ 24" O.C. W/ GALV METAL PILING HAT CHANNELS (GAUGE # 16 @ 1/2" TYP) TO BE WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER.

(150) WATER HEATER SEE PLUMBING DRAWINGS

(151) DRINKING FOUNTAIN FFR PLUMBING DUGS.

(152) FLOOR MOUNTED UTILITY SINK. SEE PLUMBING DUGS.

(153) COUNTER MOUNTED SINK. SEE PLUMBING DUGS.

(154) AIR CURTAIN. SEE MECHANICAL DRAWINGS

(160) ELECTRICAL SERVICE ENTRANCE LOCATION SEE ELECTR. DUGS

(161) ELECTRICAL SUB-PANEL. VERIFY FINAL LOCATION SEE ELECTR. DUGS

(162) TELEPHONE MOUNTING BOARD. PAINT. DUGS

(170) REFRIG. - NIC

(171) VENDING MACHINE - NIC

(172) BALER (HARTONY ENTERPRISES/ 1609TD) - NIC

(173) FORKLIFT CHARGER OUTLET. SEE ELECTRICAL DRAWINGS

(174) AIR CURTAIN. SEE MECHANICAL/ ELECTRICAL DRAWINGS

WALL SCHEDULE

SYMBOL DESCRIPTION PLAN SECTION 3/4" = 1'-0"

1 STEEL STUD WALL (GAUGE # 16) SPACING PER STEEL @ 24" O.C. W/ (1) LAYER 5/8" GYPSUM BOARD EACH OTHERSIDE

1A R-11 FIBERGLASS BATT INSULATION

2 EXTERIOR WALL 6" STEEL STUDS (GAUGE # 16) SPACING PER STRUCTL

EXTERIOR 5/8" COAT (ICC ESR-1601) WEATHER COE (KOTE) STUCCO O/ INSUL LATH O/ 1" RIGID EPS INSULATION O/ BUILDING PAPER O/ STRUCTURAL

INTERIOR (1) LAYER 5/8" GYPSUM BD INSULATION R-13 FIBERGLASS BATT BATT UNFACED

3 EXTERIOR WALL METAL BUILDING SYSTEM DESIGN PROVIDED BY MANFR W/ 4" ALL WEATHER INSULATED WALL PANELS W/ EXPOSED FINISH

FLASHERS GALV METAL FLASHING HAT CHANNELS (GAUGE # 16 @ 1/2" TYP) TO BE WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER UNO INSULATION R-13 INBL BATT @ STEEL GIRTS

4 COLUMNS 6"x6" CHU RUNNING BOND W/ REINFORCING TIG WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER UNO INSULATION R-13 INBL BATT @ STEEL GIRTS

NOTES: (1) PROVIDE UR. TYPE GYPSUM BOARD AT TOILET ROOMS, BREAKROOMS, AND UTILITY ROOM WALLS UNO. (2) PROVIDE 6" STEEL STUDS IN LEBU OF 3-3/4" STEEL STUDS AT ALL INTERIOR PLUMBING WALLS. (3) PROVIDE 20GA STEEL STUDS @ 16" O.C. MAX AT ALL WALLS RECEIVING CERAMIC TILE FINISH

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

FINISH NOTE

WALL & CEILING FINISHES:

PER IBC TABLE 603.5, GROUP B, NONSPRINKLERED, EXIT ACCESS - CLASS B & ROOMS - CLASS C.

IBC 603.1 GENERAL INTERIOR WALL AND CEILING FINISHES SHALL BE CLASSIFIED IN ACCORDANCE WITH ASTM E 84. SUCH INTERIOR FINISH MATERIALS SHALL BE GROUPED IN THE ACCORDANCE WITH THEIR FLAME SPREAD AND SMOKE DEVELOPED INDEXES.

CLASS A: FLAME SPREAD 0-25 & SMOKE DEVELOPED 0-450.

CLASS B: FLAME SPREAD 26-75 & SMOKE DEVELOPED 460-750.

INTERIOR FLOOR FINISHES:

IBC 604.2 CLASSIFICATION:

INTERIOR FLOOR FINISH AND FLOOR COVERING MATERIALS REQUIRED BY SECTION 604.5.1 TO BE OF CLASS I OR II MATERIALS SHALL BE CLASSIFIED IN ACCORDANCE WITH NFPA 253. THE CLASSIFICATION REFERRED TO HEREIN FOR CLASS I SHALL BE DETERMINED BY NFPA 253 AS FOLLOWS:

PER IBC 604.5.1, NONSPRINKLERED, EXIT ACCESS - CLASS B, ROOMS AREAS DOOR-1 MATERIALS ARE REQUIRED.

THERMAL & SOUND INSULATING MATERIALS NOTE:

IBC 119.3 CONCEALED INSTALLATION, INSULATING MATERIALS, WHERE CONCEALED AS INSTALLED IN BUILDINGS OF ANY TYPE OF CONSTRUCTION, SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED INDEX OF NOT MORE THAN 450.

KEYED NOTES

(20) IRRIGATION TIER CONTROL. SEE LANDSCAPING PLAN. VERIFY FINAL LOCATION. SEE ELEVATION 1010.0.

(21) BOLLARD. TYP.

(50) CART STORAGE BAILING SYSTEM. (CARRIAGE TRADE SERVICE CO. OR EQUAL.) 2-1/4" CHROME POSTS @ 48" O.C. AND 1-3/4" CHROME RAILS @ TOP & MIDSPAN. INSTALL PER TIER SHEET.

(100) FINE EXTINGUISHER. 2A-10BC. STAINLESS STEEL. SEMI RECESSED. BRACKET. FIELD VERIFY AND COORDINATE LOCATION.

(102) 4408BC FINE EXTINGUISHER WALL MOUNT W/ BRACKET @ 54" (MAX) A/F.F. TO TOP OF BRACKET.

(120) CHANGING ROOM ACCESSORIES: - 3" X 6" GLASS MIRROR W/ STAINLESS STEEL TRIM - (3) SEAT HOOKS IN PLASTIC LAMINATE BENCH - PLASTIC LAMINATE COUNTER TOP - 3/4" HT MAX W/ HARDWOOD EDGE AND 4" PLASTIC LAMINATE BACKSPLASH OVER LOWER CASEWORK W/ ADJUSTABLE SHELVING UNO.

ABOVE - 30" HT UPPER CASEWORK W/ ADJUSTABLE SHELVING, UNO.

SEE CASEWORK NOTES

(131) METAL BUILDING SYSTEM RAILING/SHADE DETAIL ABOVE

(132) METAL BUILDING SYSTEM GUTTER (DESIGN BY METAL BLDG MANFR) & LEADER (DESIGN BY MECHL ENGR) W/ CONCRETE FLASH BLOCK @ WIDE X (EXTEND TO FACE OF CURB) TYP AT GRADE TO PROVIDE POSITIVE DRAINAGE.

(133) STEEL GIRTS @ 24" O.C. W/ GALV METAL PILING HAT CHANNELS (GAUGE # 16 @ 1/2" TYP) TO BE WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER.

(150) WATER HEATER SEE PLUMBING DRAWINGS

(151) DRINKING FOUNTAIN FFR PLUMBING DUGS.

(152) FLOOR MOUNTED UTILITY SINK. SEE PLUMBING DUGS.

(153) COUNTER MOUNTED SINK. SEE PLUMBING DUGS.

(154) AIR CURTAIN. SEE MECHANICAL DRAWINGS

(160) ELECTRICAL SERVICE ENTRANCE LOCATION SEE ELECTR. DUGS

(161) ELECTRICAL SUB-PANEL. VERIFY FINAL LOCATION SEE ELECTR. DUGS

(162) TELEPHONE MOUNTING BOARD. PAINT. DUGS

(170) REFRIG. - NIC

(171) VENDING MACHINE - NIC

(172) BALER (HARTONY ENTERPRISES/ 1609TD) - NIC

(173) FORKLIFT CHARGER OUTLET. SEE ELECTRICAL DRAWINGS

(174) AIR CURTAIN. SEE MECHANICAL/ ELECTRICAL DRAWINGS

WALL SCHEDULE

SYMBOL DESCRIPTION PLAN SECTION 3/4" = 1'-0"

1 STEEL STUD WALL (GAUGE # 16) SPACING PER STEEL @ 24" O.C. W/ (1) LAYER 5/8" GYPSUM BOARD EACH OTHERSIDE

1A R-11 FIBERGLASS BATT INSULATION

2 EXTERIOR WALL 6" STEEL STUDS (GAUGE # 16) SPACING PER STRUCTL

EXTERIOR 5/8" COAT (ICC ESR-1601) WEATHER COE (KOTE) STUCCO O/ INSUL LATH O/ 1" RIGID EPS INSULATION O/ BUILDING PAPER O/ STRUCTURAL

INTERIOR (1) LAYER 5/8" GYPSUM BD INSULATION R-13 FIBERGLASS BATT BATT UNFACED

3 EXTERIOR WALL METAL BUILDING SYSTEM DESIGN PROVIDED BY MANFR W/ 4" ALL WEATHER INSULATED WALL PANELS W/ EXPOSED FINISH

FLASHERS GALV METAL FLASHING HAT CHANNELS (GAUGE # 16 @ 1/2" TYP) TO BE WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER UNO INSULATION R-13 INBL BATT @ STEEL GIRTS

4 COLUMNS 6"x6" CHU RUNNING BOND W/ REINFORCING TIG WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER UNO INSULATION R-13 INBL BATT @ STEEL GIRTS

NOTES: (1) PROVIDE UR. TYPE GYPSUM BOARD AT TOILET ROOMS, BREAKROOMS, AND UTILITY ROOM WALLS UNO. (2) PROVIDE 6" STEEL STUDS IN LEBU OF 3-3/4" STEEL STUDS AT ALL INTERIOR PLUMBING WALLS. (3) PROVIDE 20GA STEEL STUDS @ 16" O.C. MAX AT ALL WALLS RECEIVING CERAMIC TILE FINISH

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

SEE WALL TYPE 2 FOR WALL CONSTRUCTION ABOVE

FINISH NOTE

WALL & CEILING FINISHES:

PER IBC TABLE 603.5, GROUP B, NONSPRINKLERED, EXIT ACCESS - CLASS B & ROOMS - CLASS C.

IBC 603.1 GENERAL INTERIOR WALL AND CEILING FINISHES SHALL BE CLASSIFIED IN ACCORDANCE WITH ASTM E 84. SUCH INTERIOR FINISH MATERIALS SHALL BE GROUPED IN THE ACCORDANCE WITH THEIR FLAME SPREAD AND SMOKE DEVELOPED INDEXES.

CLASS A: FLAME SPREAD 0-25 & SMOKE DEVELOPED 0-450.

CLASS B: FLAME SPREAD 26-75 & SMOKE DEVELOPED 460-750.

INTERIOR FLOOR FINISHES:

IBC 604.2 CLASSIFICATION:

INTERIOR FLOOR FINISH AND FLOOR COVERING MATERIALS REQUIRED BY SECTION 604.5.1 TO BE OF CLASS I OR II MATERIALS SHALL BE CLASSIFIED IN ACCORDANCE WITH NFPA 253. THE CLASSIFICATION REFERRED TO HEREIN FOR CLASS I SHALL BE DETERMINED BY NFPA 253 AS FOLLOWS:

PER IBC 604.5.1, NONSPRINKLERED, EXIT ACCESS - CLASS B, ROOMS AREAS DOOR-1 MATERIALS ARE REQUIRED.

THERMAL & SOUND INSULATING MATERIALS NOTE:

IBC 119.3 CONCEALED INSTALLATION, INSULATING MATERIALS, WHERE CONCEALED AS INSTALLED IN BUILDINGS OF ANY TYPE OF CONSTRUCTION, SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED INDEX OF NOT MORE THAN 450.

KEYED NOTES

(20) IRRIGATION TIER CONTROL. SEE LANDSCAPING PLAN. VERIFY FINAL LOCATION. SEE ELEVATION 1010.0.

(21) BOLLARD. TYP.

(50) CART STORAGE BAILING SYSTEM. (CARRIAGE TRADE SERVICE CO. OR EQUAL.) 2-1/4" CHROME POSTS @ 48" O.C. AND 1-3/4" CHROME RAILS @ TOP & MIDSPAN. INSTALL PER TIER SHEET.

(100) FINE EXTINGUISHER. 2A-10BC. STAINLESS STEEL. SEMI RECESSED. BRACKET. FIELD VERIFY AND COORDINATE LOCATION.

(102) 4408BC FINE EXTINGUISHER WALL MOUNT W/ BRACKET @ 54" (MAX) A/F.F. TO TOP OF BRACKET.

(120) CHANGING ROOM ACCESSORIES: - 3" X 6" GLASS MIRROR W/ STAINLESS STEEL TRIM - (3) SEAT HOOKS IN PLASTIC LAMINATE BENCH - PLASTIC LAMINATE COUNTER TOP - 3/4" HT MAX W/ HARDWOOD EDGE AND 4" PLASTIC LAMINATE BACKSPLASH OVER LOWER CASEWORK W/ ADJUSTABLE SHELVING UNO.

ABOVE - 30" HT UPPER CASEWORK W/ ADJUSTABLE SHELVING, UNO.

SEE CASEWORK NOTES

(131) METAL BUILDING SYSTEM RAILING/SHADE DETAIL ABOVE

(132) METAL BUILDING SYSTEM GUTTER (DESIGN BY METAL BLDG MANFR) & LEADER (DESIGN BY MECHL ENGR) W/ CONCRETE FLASH BLOCK @ WIDE X (EXTEND TO FACE OF CURB) TYP AT GRADE TO PROVIDE POSITIVE DRAINAGE.

(133) STEEL GIRTS @ 24" O.C. W/ GALV METAL PILING HAT CHANNELS (GAUGE # 16 @ 1/2" TYP) TO BE WELDED TO 6" AFF & 5/8" GYPSUM BOARD FROM 10" AFF TO TOP OF WALL @ INTER.

(150) WATER HEATER SEE PLUMBING DRAWINGS

(151) DRINKING FOUNTAIN FFR PLUMBING DUGS.

(152) FLOOR MOUNTED UTILITY SINK. SEE PLUMBING DUGS.

(153) COUNTER MOUNTED SINK. SEE PLUMBING DUGS.

(154) AIR CURTAIN. SEE MECHANICAL DRAWINGS

(160) ELECTRICAL SERVICE ENTRANCE LOCATION SEE ELECTR. DUGS

(161) ELECTRICAL SUB-PANEL. VERIFY FINAL LOCATION SEE ELECTR. DUGS

(162) TELEPHONE MOUNTING BOARD. PAINT. DUGS

(170) REFRIG. - NIC

(171) VENDING MACHINE - NIC

(172) BALER (HARTONY ENTERPRISES/ 1609TD) - NIC

(173) FORKLIFT CHARGER OUTLET. SEE ELECTRICAL DRAWINGS

(174) AIR CURTAIN. SEE MECHANICAL/ ELECTRICAL DRAWINGS

FINISH NOTE

WALL & CEILING FINISHES:

PER IBC TABLE 603.5, GROUP B, NONSPRINKLERED, EXIT ACCESS - CLASS B & ROOMS - CLASS C.

IBC 603.1 GENERAL INTERIOR WALL AND CEILING FINISHES SHALL BE CLASSIFIED IN ACCORDANCE WITH ASTM E 84. SUCH INTERIOR FINISH MATERIALS SHALL BE GROUPED IN THE ACCORDANCE WITH THEIR FLAME SPREAD AND SMOKE DEVELOPED INDEXES.

CLASS A: FLAME SPREAD 0-25 & SMOKE DEVELOPED 0-450.

CLASS B: FLAME SPREAD 26-75 & SMOKE DEVELOPED 460-750.

INTERIOR FLOOR FINISHES:

IBC 604.2 CLASSIFICATION:

INTERIOR FLOOR FINISH AND FLOOR COVERING MATERIALS REQUIRED BY SECTION 604.5.1 TO BE OF CLASS I OR II MATERIALS SHALL BE CLASSIFIED IN ACCORDANCE WITH NFPA 253. THE CLASSIFICATION REFERRED TO HEREIN FOR CLASS I SHALL BE DETERMINED BY NFPA 253 AS FOLLOWS:

PER IBC 604.5.1, NONSPRINKLERED, EXIT ACCESS - CLASS B, ROOMS AREAS DOOR-1 MATERIALS ARE REQUIRED.

THERMAL & SOUND INSULATING MATERIALS NOTE:

IBC 119.3 CONCEALED INSTALLATION, INSULATING MATERIALS, WHERE CONCEALED AS INSTALLED IN BUILDINGS OF ANY TYPE OF CONSTRUCTION, SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED INDEX OF NOT MORE THAN 450.

KEYED NOTES

(20) IRRIGATION TIER CONTROL. SEE LANDSCAPING PLAN. VERIFY FINAL LOCATION. SEE ELEVATION 1010.0.

(21) BOLLARD. TYP.

(50) CART STORAGE BAILING SYSTEM. (CARRIAGE TRADE SERVICE CO. OR EQUAL.) 2-1/4" CHROME POSTS @ 48" O.C. AND 1-3/4" CHROME RAILS @ TOP & MIDSPAN. INSTALL PER TIER SHEET.

(100) FINE EXTINGUISHER. 2A-10BC. STAINLESS STEEL. SEMI RECESSED. BRACKET. FIELD VERIFY AND COORDINATE LOCATION.

(102) 4408BC FINE EXTINGUISHER WALL MOUNT W/ BRACKET @ 54" (MAX) A/F.F. TO TOP OF BRACKET.

(120) CHANGING ROOM ACCESSORIES: - 3" X 6" GLASS MIRROR W/ STAINLESS STEEL TRIM - (3) SEAT HOOKS IN PLASTIC LAMINATE BENCH - PLASTIC LAMINATE COUNTER TOP - 3/4" HT MAX W/ HARDWOOD EDGE AND 4" PLASTIC LAMINATE BACKSPLASH OVER LOWER CASEWORK W/ ADJUSTABLE SHELVING UNO.

ABOVE - 30" HT UPPER CASEWORK W/ ADJUSTABLE SHELVING, UNO.

SEE CASEWORK NOTES

(131) METAL BUILDING SYSTEM RAILING/SHADE DETAIL ABOVE

(132) METAL BUILDING SYSTEM GUTTER (DESIGN BY METAL BLDG MANFR)